NOTICE

Utility Interactive photovoltaic & windmill Systems

Renewable energy sources need to be permitted and inspected

The Pennsylvania Uniform Construction Code section 403.1 (b) (3) &403.62(c)

International Residential Code 2006 section 105.2

Local zoning ordinances as adopted by the municipally

Certification letter signed and sealed by Pennsylvania structural engineer for the following:

- 1) Existing or new roof structure will support weight of added solar panels.
- 2) Fastening of solar panels to roof will meet potential wind uplift.
- 3) Foundation design/construction for windmills

Systems must meet minimum standards of the:

- 1) NEC and IRC Codes & Pennsylvania Uniform Construction Code
- 2) Modules UL 1703
- 3) Inverters UL 1744
- 4) Approved by local utility company

Utility contacts:

Met. Ed, Mr. Bruce Remmel - phone # 610.921.6839 Adams Electric, Mr. Terry Hancock - phone # 717.334.2171

Geothermal systems

Renewable energy sources need to be permitted and inspected

The Pennsylvania Uniform Construction Code section 403.1(b)(8)

Local well ordinances as adopted by the municipally

Required by design:

- 1) Structure alterations to the existing building
- 2) Exit changes to the existing building.
- 3) Well placement (location) and installation.